

# Certificate of Compliance

**Certificate:** 182337 - 2500005460 (LR 93580)

**Project:** 2500005460

**Date Issued:** January 14, 2000

**Issued To:** Atlas Transformer Inc.  
7131 Edwards Blvd.  
Mississauga, ON L5S 1Z2  
Attn: Mr. Ernest Tan

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** J. Beacham

**Signature:** \_\_\_\_\_

## PRODUCTS

CLASS 5411 06 - TRANSFORMERS - Power

Dry type power and lighting circuit transformers and auto transformers. Class 185C (80C and 115C rise) and Class 220C (80C, 115C and 150C rise) insulation, up to 34.5kV voltage class, 60Hz, 1 and 3 ph, 12,000kVA max as follows:

- Open core and coil
- ANN (enclosed, ventilated)
- AFN (enclosed, ventilated, fan cooled)
- Weatherproof, Type 3R

## Notes:

1. Open core and coil types are intended for use in other equipment where the suitability of the combination is to be determined.
2. For Type AFN (fan cooled, ventilated enclosures) the kVA output may be increased by up to 33 percent

## APPLICABLE STANDARDS

The product, as described in this report, complies with:

CAN/CSA-C22.2 No.	0-M91	-	General Requirements - Canadian Electrical Code, Part II
CSA Std C22.2 No.	0.4-M1982	-	Bonding and Grounding of Electrical Equipment (Protective Grounding)
CAN/CSA-C22.2 No.	47-M90	-	Air-Cooled Transformers (Dry-Type)
CAN/CSA-C22.2 No.	94-M91	-	Special Purpose Enclosures